EMONA INSTRUMENTS PTY LTD

EMONA Instruments Pty Ltd
78 Parramatta Road
Camperdown 2050

www.instaltest.com.au

Mustafa Keskin
Electrical Product Manager
02 9519 3999

testinst@emona.com.au

Instrument data:

Model: MI 3152 Serial Number: 15450146 Calibration date: 10/02/2016
User:

Model: Virtual Instrument Serial Number: Calibration date:
User:

EMONA /78 Parramatta Rd/MB1/DB1/CB1/RCD1/RCD push button test			Pass
Log PUSH button		Pass	
EMONA /78 Parramatta Rd/MB1/DB1/CB2/RCD2/RCD push button test			Pass
Log PUSH button		Pass	
EMONA /78 Parramatta Rd/MB1/DB1/CB3/RCD3/RCD push button test			Pass
Log PUSH button		Pass	
EMONA /78 Parramatta Rd/MB1/DB1/CB4/RCD MEDICAL/RCD t			Pass
Results			
t ΔN		26.9 ms	
SubResults			
Uc		2.2 V	
Phase		87 °	
EMONA /78 Parramatta Rd/MB1/DB1/CB5/RCD5/RCD t			Pass
Results			
t IΔN, (+)		58.3 ms	
t IΔN, (-)		58.2 ms	
SubResults			
Uc		2.4 V	
EMONA /78 Parramatta Rd/MB1/DB1/CB6/Installation WITH RCD LIVE			Pass
AUTO TN (RCD)		Pass	
Results			
Uln	245 V		
Z (LPE)	1.06 Ω	Pass	
Z (LN)	0.70 Ω	Pass	
Ipsc (LN)	328 A		
Ipsc (LPE)	217 A		
Rpe	0.65 Ω	Pass	
EMONA /78 Parramatta Rd/MB1/DB1/CB6/R low			Fail
Results			
R		>1999 Ω	Fail
SubResults			

Signature: Created date: 10/03/2017